

PJ-AA X-171
ISN 50266

CONTRACTOR REPORT

SAND85-7018/1
Unlimited Release
UC-63

Evaluation of International Photovoltaic Projects

Volume I: Executive Summary

D. Eskenazi, D. Kerner, L. Slominski
Meridian Corporation
Falls Church, VA 22041

This program was sponsored jointly by
Division of Photovoltaic Energy Technology
United States Department of Energy
and
Office of Energy
Bureau for Science and Technology
U.S. Agency for International Development

Prepared by Sandia National Laboratories Albuquerque, New Mexico 87185
and Livermore, California 94550 for the United States Department of Energy
under Contract DE-AC04-76DP00789

Printed September 1986

SAND85-7018/1
Unlimited Release
Printed September 1986

Distribution
Category UC-63

Evaluation of International Photovoltaic Projects

Volume 1: Executive Summary

D. Eskenazi, D. Kerner, L. Slominski
Meridian Corporation
Falls Church, VA 22041

Sandia Contract No. 21-3488

Abstract

This report provides a comprehensive review and financial analysis of photovoltaic power systems for remote applications in developing countries. Volume I, the Executive Summary, provides an overview of all findings; Volume II, the Technical Report, covers the methods of analysis used and the results obtained. Five application areas are included: water pumping, communications, vaccine refrigeration, lighting and home power, and multi-use systems. Findings are based on qualitative reviews of more than 2700 systems in 45 countries. Information was collected from published reports, questionnaires, and interviews with key experts. Site visits were not within the scope of this evaluation. The intended audience of this report are development agency officials, manufacturers, and users. Based on "lessons learned" from past projects, recommendations are provided for project implementation. In addition, financial analyses allow decision makers to use their own assumptions to obtain a first-order indication of the financial attractiveness of photovoltaic systems for each application. This report also provides industry with an assessment of product performance and suggested areas for additional improvements.

ACKNOWLEDGEMENTS

Brad Macaleer served as project manager for this report. Most of the technical work was performed by Lawrence Slominski and Deborah Eskenazi. Substantial support was also provided by several others on Meridian's staff, including David Kerner, Brenda Platt, and George Royal. Technical editing was provided by Catherine Keightley. Typing support was provided by Doris Ellmore.

One subcontractor and two consultants also provided technical inputs. I.T. Power, Incorporated, of Washington, D.C., provided most of the technical information on vaccine refrigeration systems. Matt Buresch and Barry Welch developed the system sizing and financial models used in the analysis.

This report could not have been completed in a credible manner without the unselfish input and support of many experts. Among those who provided substantial assistance are Anthony Ratajczak of NASA-Lewis Research Center, Bill Kaszeta of Solavolt International, Alfonso Zavala of the World Bank, Derek Lovejoy of the United Nations, and John Eckel of A.Y. McDonald.

The authors would like to thank Hal Post of Sandia National Laboratories for his endless patience and strong technical direction in monitoring this work. Special recognition is also in order for those who had the foresight to sponsor this report. Jack Vanderryn of the U.S. Agency for International Development provided the initial sponsorship of this report; Bud Annan, Director of the Photovoltaic Energy Technology Division of the U.S. Department of Energy, provided both the financial and moral support necessary to complete this project.

TABLE OF CONTENTS

VOLUME I: EXECUTIVE SUMMARY

	<u>Page</u>
1.0 OVERVIEW	1
1.1 Background	1
1.2 Purpose	2
2.0 METHODOLOGY	5
3.0 EVALUATION FINDINGS	7
3.1 Water Pumping	10
3.2 Communications	13
3.3 Vaccine Refrigeration	16
3.4 Lighting and Home Power	19
3.5 Multi-Use Systems	22
4.0 RECOMMENDATIONS	25
4.1 Technical	25
4.2 Institutional	27
4.3 Financial	28

LIST OF EXHIBITS

<u>Exhibit</u>	<u>Page</u>
E-1 Systems Experience Reviewed	3
E-2 Technologies Compared in Life-Cycle Analyses	4
E-3 Load Specifications for Base-Case Analyses	4
E-4 Common Base-Case Financial Assumptions	6
E-5 Common Base-Case Technical Assumptions	6
E-6 Evaluation Findings	8
E-7 PV Financial Viability Limits	9
E-8 Pumping: Base Case	10
E-9 Sensitivity of Pumping Costs	12
E-10 Base-Case Water Pumping System	12
E-11 Communications: Base Case	13
E-12 Sensitivity of Communications Costs	15
E-13 Base-Case Communications System	15
E-14 Refrigeration: Base Case	16
E-15 Sensitivity of Refrigeration Costs	18
E-16 Base-Case Refrigeration System	18
E-17 Lighting and Home Power: Base Case	19
E-18 Sensitivity of Home Power Costs	21
E-19 Base-Case Lighting and Home Power	21
E-20 Multi-Use: Base Case	22
E-21 Sensitivity of Multi-Use System Costs	24
E-22 Base-Case Multi-Use System	24
E-23 Recommendations	26

LIST OF ACRONYMS

AC	- Alternating current
CDC	- Centers for Disease Control
CIF	- Cost, insurance, and freight
DC	- Direct current
EPI	- Expanded Programme on Immunization
FOB	- Free on board
HED	- Hydraulic energy demand
kWh	- Kilowatt-hour
LDC	- Lesser developed countries
NPV	- Net present value
O&M	- Operation and maintenance
PV	- Photovoltaic
SNLA	- Sandia National Laboratories - Albuquerque
SPEC	- South Pacific Bureau for Economic Cooperation
USAID	- U.S. Agency for International Development
USDOE	- U.S. Department of Energy
UNDP	- United Nations Development Programme
WHO	- World Health Organization
W_p	- Peak watt (power output under standard rating conditions - $1,000 \text{ W/m}^2$ insolation at 25°C cell temperature)

EXECUTIVE SUMMARY

1.0 OVERVIEW

1.1 Background

During the last decade, governments, donor agencies, and nonprofit organizations have sponsored PV projects in developing countries to test, evaluate, and demonstrate the performance of PV as an energy technology for remote areas of the developing world. These PV-powered systems have provided electricity for water pumping, communications, refrigeration, lighting, and other basic necessities to people and areas that have never before had power.

Despite this increased use of PV-powered systems in developing countries, no attempt has been made to systematically analyze the cost and performance experiences of PV systems in this environment. Hence, there existed a need for a comprehensive and objective evaluation of the viability of PV systems for various applications in developing countries. It is toward this end that this evaluation is conducted.

This report is directed towards development agency officials, suppliers, and users of PV systems. Since quantitative performance data are not available, the report is based primarily on subjective information. It provides development agency officials with the information required to assess PV projects and with "lessons learned" recommendations for project implementation. The report also provides an assessment of potential applications as well as an evaluation of product performance and suggested areas for improvement. Users will learn from past experiences and will be provided with a methodology for making a rough comparison between PV and other technologies.

This work was performed by Meridian Corporation under contract to Sandia National Laboratories-Albuquerque (SNLA) and was supported by the U.S. Agency for International Development (USAID) and the U.S. Department of Energy (USDOE).

Purpose

The purpose of this report is twofold:

- To review the qualitative experience associated with the use of PV-powered systems in developing country applications.
- To educate decision-makers on the viability of PV systems for various developing country applications.

To meet this dual purpose, the full report provides the following:

- A summary of field experience of PV-powered systems in developing countries. The experience associated with more than 2700 systems in 45 countries was reviewed across 5 applications (see Exhibit E-1).
- A discussion of current designs and costs for both PV- and conventional-powered systems. Because photovoltaic systems have been rapidly improving in both performance and cost, past systems may not be completely representative of today's technology. To facilitate an up-to-date comparison of PV to other systems, recent system improvements and current costs were obtained from system suppliers and recent tenders.
- Financial analyses for comparing PV-powered systems to conventional alternatives. The cost of PV systems was compared to the most likely alternative system using a net present value (NPV) life-cycle costing methodology that is consistent with World Bank standards. Exhibits E-2 and E-3 identify the technologies and base-case systems that were compared for each application. Sensitivity analyses were conducted to demonstrate the impact of key parameters on system life-cycle cost.

Exhibit E-1
SYSTEMS EXPERIENCE REVIEWED

APPLICATION	NUMBER OF SYSTEMS	NUMBER OF COUNTRIES
Water Pumping	> 194	22
Communications	>1100	14
Vaccine Refrigeration	> 105	43
Lighting and Home Power	>1260	14
Multi-Use	42	22
Total:	>2700*	>45 *

* Total reflects overlap in subtotals.

Exhibit E-2
TECHNOLOGIES COMPARED IN LIFE-CYCLE ANALYSES

APPLICATION	POWER SOURCE			
	PV	DIESEL	KEROSENE	BATTERIES
Water Pumping	X	X		
Communications	X	X		
Vaccine Refrigeration	X		X	
Lighting and Home Power	X		X	X
Multi-Use	X	X		

Exhibit E-3
LOAD SPECIFICATIONS FOR BASE-CASE ANALYSES

APPLICATION	SPECIFICATION
Water Pumping	<ul style="list-style-type: none"> • Village drinking water system • 50 m³/day average water demand • 25-meter head
Communications	<ul style="list-style-type: none"> • Microwave repeater application • 7.2 kWh/day continuous load
Vaccine Refrigeration	<ul style="list-style-type: none"> • Vaccine Refrigeration • Two cases: <ul style="list-style-type: none"> - Small (24 liters) - Large (68-80 liters)
Lighting and Home Power	<ul style="list-style-type: none"> • Three cases: <ul style="list-style-type: none"> • Small - one light • Medium - two lights • Large - two lights and a radio
Multi-Use	<ul style="list-style-type: none"> • 10 kWh/day average demand over a period of 12 to 15 hours

The experience associated with more than 2,700 PV systems was incorporated into this evaluation. From these 2,700 systems, 29 specific projects were selected for detailed review. Performance information was collected from three principal sources: project reports and articles; questionnaires sent to end-users and/or participating in-country personnel; and interviews with manufacturers and other key individuals. (Questionnaires were sent to over 300 organizations and individuals to obtain field performance data and end-user perceptions about the viability of PV in developing countries; 20 percent of those receiving questionnaires responded.) The evaluation was conducted with the understanding that quantitative field performance data are limited, and what little data exist are of questionable accuracy.

Once all data were collected and analyzed, NPV life-cycle cost comparisons of photovoltaic-powered systems and the most likely conventional alternative system were performed for each of the five application areas (water pumping, communications, vaccine refrigeration, lighting and home power, and multi-use). NPV life-cycle cost analyses are presented as 20-year cash flows comparing the conventional alternative to PV using specific base-case assumptions. The common base-case financial and technical assumptions are presented in Exhibits E-4 and E-5. Sensitivity analyses were performed to estimate the comparative viability of PV and conventional alternatives based on particular country-specific parameters. All applications include a PV array cost (FOB) of \$8.00 per peak watt. Parameters analyzed include equipment capital cost, discount rate, conventional fuel cost, diesel lifetime, insolation, kerosene refrigerator operating availability, and annual vaccine dose requirements.

Viability ranges for each of the five applications were developed by simultaneously varying the sensitivity parameters. The parameters were adjusted to reasonable extremes (lowest discount and interest rate, highest fuel cost, shortest conventional system lifetime, and highest insolation) in the best PV case scenario and to their opposite extremes in the worst PV case scenario. These viability ranges were included to provide a general picture of the circumstances under which PV systems are financially attractive.

EXHIBIT E-4
COMMON BASE-CASE FINANCIAL ASSUMPTIONS

PARAMETER	ASSUMPTION
Debt Service	<ul style="list-style-type: none"> • 100% financing of system initial capital CIF cost • 20-year term • 10% per year (compounded at the end of the year)
Salvage Value	• Included
Installation Costs	• Not included
Operating Labor	• Not included
Diesel Fuel Cost	• \$0.50 per liter
Kerosene Fuel Cost	• \$0.70 per liter
General Inflation	• 5% per year
Nominal Discount and Interest Rate	• 10% per year

Exhibit E-5
COMMON BASE-CASE TECHNICAL ASSUMPTIONS

SPECIFICATION	SYSTEM TYPE		
	PV	DIESEL	KEROSENE
Component Life (Years)			
- Array	20	NA	NA
- Gen-Set	NA	6	NA
- Power Conditioning	10	10	NA
- Batteries	5	5	2*
- Loads	5	5	10 - refrig. 3 - lights
Major Maintenance			
- Engine Overhaul	NA	every 3 years	NA

NA - Not applicable

* - Batteries used in conventional home power systems

Across the five applications examined in this evaluation, the majority of PV-powered systems have been well accepted by users based on their reliability, independence from fuel, and minimal maintenance requirements. Although early systems experienced some technical problems, advancements in current equipment are resulting in more reliable systems. The major limitations to implementing PV systems for developing countries are institutional support and the lack of long-term financing. The evaluation findings are summarized in Exhibit E-6.

Exhibit E-7 graphically represents the financial viability of PV systems across all five of the selected applications (water pumping, communications, vaccine refrigeration, lighting and home power, and multi-use). "PV Least Cost" indicates the load range at which PV is the least-cost option even under unfavorable financial assumptions. Similarly, "Diesel Least Cost" indicates when diesel is the least-cost option even under assumptions favorable to PV. The "Break-Even Range" depicts the load range in which either PV or the alternative could be the least-cost option, depending on the parameter values selected.

EXHIBIT E-6. EVALUATION FINDINGS

TECHNICAL PERFORMANCE

Stand-alone PV-powered systems have been well accepted by users based on their reliability, independence from fuel, and minimal maintenance requirements.

- PV arrays are nearly 100 percent reliable.
- The performance of power conditioning and end-use equipment has varied, but the careful selection of field-proven components should ensure successful system operation. Diesel, gasoline, and kerosene systems face the same problem.


INSTITUTIONAL SUPPORT

Institutional support for PV-powered systems has been the overall weak link in implementing these systems in developing countries. Because PV is a relatively new technology, there is no established infrastructure to support training, maintenance, and repair. However, in cases where institutional support is lacking for both PV and conventional systems, PV-powered systems are more successful due to their lower operation, maintenance, and repair requirements.

FINANCIAL VIABILITY

- For loads smaller than 1 kilowatt, PV-powered systems are the least-cost option, on a life-cycle cost basis, for stand-alone water pumping, communications, vaccine refrigeration, lighting and home power, and multi-use systems when compared to diesel-, gasoline-, and kerosene-powered systems. This is largely because diesel engines are not available at sizes below 3 kilowatts for developing country applications.
- For loads between 1 and 20 kilowatts, a case-specific financial analysis is necessary to determine the least-cost option.
- For loads greater than 20 kilowatts, PV-powered systems are not generally the least-cost option. However, certain PV-powered system benefits often mentioned by users (such as reliability and independence from fuel) cannot be quantified. PV systems have been justified based on these subjective criteria.
- These financial viability findings are supported by the financial analyses performed as part of this evaluation and by case studies of programs that have stimulated the widespread implementation of PV-powered systems through financing.

Exhibit E-7 PV FINANCIAL VIABILITY LIMITS **(Average Energy Demand and Relative PV Array Sizes)**



*PV Array is smaller for large refrigerator due to peculiarities in the World Health Organization specifications.

3.1 Water Pumping

For this evaluation, the cost of PV-powered water pumping systems is compared to diesel-powered systems for rural water supply, assuming development agency financing. Exhibit E-8 provides the base-case parameters used in this comparison. PV-powered water pumping systems are conservatively determined to be financially competitive to diesel-powered systems up to demands of 25 m³/day at a 25-meter head, even under unfavorable financial assumptions. This is equivalent to demands of up to 625 m⁴/day, where m⁴/day refers to the volume of water pumped multiplied by the head. Systems with demands ranging from 25 to 550 m³/day at a head of 25 meters are in the break-even range, with PV system viability dependent on case-specific parameters. Above this range, PV-powered water pumping systems are not financially viable at the present time.

Exhibit E-8 **PUMPING: BASE CASE**

SPECIFICATIONS:

- Village Drinking Water System
- 50 m³/day Average Daily Demand (supplies 2500 people)
- 25 Meter Head

	PV SYSTEM	DIESEL SYSTEM
<u>TECHNICAL</u>		
• SYSTEM CONFIGURATION	2.3 kWp PV array DC motor/pump	6.4 kW diesel gen-set AC motor/pump
<u>FINANCIAL</u>		
• INITIAL CAPITAL COST (FOB)	\$19,784	\$8,318
• RECURRING CAPITAL COSTS	\$1,635 every 5 years	\$6,754 every 6 years \$1,564 every 5 years 15% every 3 years
• MAINTENANCE & REPAIR	1% per year	2% per year
• FUEL COSTS	NA	\$552 per year
<u>RESULTS</u>		
• NPV OF 20-YEAR CASH FLOW	\$31,166	\$38,021
• ANNUAL WATER PUMPED	17,338 m ³	17,338 m ³

The graph in Exhibit E-9 depicts the ratio of PV- to diesel-powered pumping system NPV costs for the best PV case and worst PV case scenarios. Both scenarios assume 20-year life-cycle costing and development agency financing. At an NPV cost ratio of 1.0, PV and diesel system life-cycle costs are equal. Under the best PV case scenario, the five parameters shown on the graph are adjusted to "reasonable extremes" that favor PV systems. An opposite adjustment is made under the worst PV case scenario. The area between the two curves represents a reasonable range of financial assumptions.

This range indicates that PV-powered pumping systems are the least-cost option at loads more than twice as great as those shown in a 1983 UNDP/World Bank pumping study for rural water supply. (The UNDP/World Bank study has been accepted by applications experts as being very conservative.) It showed PV systems to be competitive up to 250 m⁴/day as opposed to the 625 to 13,750 m⁴/day demonstrated in this report. The major reasons for this difference are: (1) the assumption of 20-year development bank financing; (2) the consideration of diesel system inefficiencies when the system is operated substantially below rated capacity; and (3) recent improvements in the cost and performance of PV systems.

Exhibit E-10 depicts the various cost elements of PV- and diesel-powered pumping systems. The sensitivity analyses indicate that diesel gen-set lifetime, fuel cost, discount and interest rate, insolation, and pumping head all have a strong impact on the cost analysis, with diesel gen-set lifetime and discount and interest rate being the most sensitive parameters. While PV-powered system costs have been dominated by debt service, diesel-powered system costs are primarily dependent on replacement and fuel costs.

The overall viability of PV-powered water pumping systems is also a function of technical and institutional performance. Successful systems have incorporated careful selection of pumps, motors, and controls. The availability and proper use of credible data on solar resources and well yield characteristics has helped to avoid significantly oversized and undersized systems. Previous studies have shown that effective training corrects misconceived user expectations and reduces system downtime.

Exhibit E-9

SENSITIVITY OF PUMPING COSTS TO BEST AND WORST CONDITIONS





Exhibit E-10

BASE-CASE WATER PUMPING SYSTEM COST COMPONENTS



PV-powered communications systems have been proven reliable and financially viable, as evidenced by the recent substantial growth in the number of commercial PV systems. For this evaluation, the cost of PV- and diesel-powered microwave repeater systems were compared assuming development agency financing. Exhibit E-11 provides the base-case parameters used in this comparison. PV-powered systems are the least-cost option up to 5 kWh/day continuous load, even under unfavorable financial assumptions. Loads of 5 kWh/day to 24 kWh/day are in the break-even range, or dependent on case-specific parameters.

Exhibit E-11

COMMUNICATIONS: BASE CASE

SPECIFICATIONS:

- Microwave Repeater Station
- 7.2kWh/day Constant, Continuous Load

	PV SYSTEM	DIESEL SYSTEM
<u>TECHNICAL</u>		
• SYSTEM CONFIGURATION	2.3 kWp PV array 63 kWh battery storage charge controller	two 3 kW diesel gen-set 9 kWh battery storage battery charger
<u>FINANCIAL</u>		
• INITIAL CAPITAL COST (FOB)	\$28,541	\$10,891
• RECURRING CAPITAL COSTS	\$9,450 every 5 years \$909 every 10 years	\$9,541 every 6 years \$1,350 every 5 years 15% every 3 years
• MAINTENANCE & REPAIR	0.05% per year	2% per year
• FUEL COSTS	NA	\$3,408 per year
<u>RESULTS</u>		
• NPV OF 20-YEAR CASH FLOW	\$59,230	\$86,529
• ANNUAL ENERGY GENERATION	2,625 kWh	2,625 kWh

The graph in Exhibit E-12 depicts the ratio of PV- to diesel-powered communications life-cycle costs for the best PV case and worst PV case scenarios. Both scenarios assume 20-year life-cycle costing and development agency financing. At an NPV cost ratio of 1.0, PV and diesel system life-cycle costs are equal. Under the best PV case scenario, the five parameters shown on the graph are adjusted to "reasonable extremes" that favor PV systems. An opposite adjustment is made under the worst PV case scenario. The area between the two curves represents a reasonable range of financial assumptions.

Exhibit E-13 depicts the various cost elements of PV- and diesel-powered microwave repeater systems. The parameters with the largest impact on the viability of PV-powered systems are discount and interest rate, diesel fuel cost and diesel lifetime. The least sensitive parameter for this application is insolation, since PV-powered system costs are dominated by battery costs, not PV array costs. Life-cycle costs for PV-powered systems are split evenly between debt service (initial system cost) and replacement costs. Although a sensitivity analysis was not performed on battery life, the high percentage of replacement costs suggests that battery life is an important parameter. Diesel-powered system life-cycle costs are dominated by fuel cost, followed by replacement costs.

Overall reliability of PV-powered communications systems is dependent on selecting charge controllers and load equipment that have been field-proven under the appropriate environmental conditions. The importance of carefully selecting load equipment is not unique to PV, but applies to conventional systems as well.

Exhibit E-12
SENSITIVITY OF COMMUNICATIONS
COSTS TO TEST AND WORST CONDITIONS




Exhibit E-13
BASE-CASE COMMUNICATIONS SYSTEMS
COST COMPONENTS



3.3

Vaccine Refrigeration

For this evaluation, the cost of PV-powered vaccine refrigeration systems was compared to kerosene-fueled refrigerators, assuming development agency financing. Exhibit E-14 provides the base-case parameters used in this comparison. The financial analyses do not indicate a clear-cut preference between PV-powered and kerosene-powered vaccine refrigeration systems. PV-powered system viability, for both small and large systems, is always in the break-even range, dependent on case-specific parameters.

Exhibit E-14

REFRIGERATION : BASE CASE

SPECIFICATIONS:

- Vaccine Refrigeration (No Ice-Pack Freezing)
- Vaccine Cost \$19/Liter
- 50 Liters Per Year Vaccine Application Level
- Insolation Level 5.8 - 7.0 kWh/m²-day

	PV SYSTEM	KEROSENE SYSTEM
<u>TECHNICAL</u>		
• SYSTEM CONFIGURATION	small [large] 24 [80] liters refrigerator 198 [168] Wp PV array* 5.5 [3.6] kWh battery storage	small [large] 24 [68] liters refrigerator fuel consumption = .2 [.7] liters/day
<u>FINANCIAL</u>		
• INITIAL CAPITAL COST (FOB)	\$3,500 [\$4,781]	\$552 [\$458]
• RECURRING CAPITAL COSTS	\$821 [\$540] every 5 years \$1,096 [\$2,897] every 10 years	\$552 [\$458] every 5 years
• MAINTENANCE & REPAIR	1% per year	10% per year
• FUEL COSTS	NA	\$51 [\$179] per year
• VACCINE WASTAGE	2.6 liters	26 liters
<u>RESULTS</u>		
• NPV OF 20-YEAR CASH FLOW	\$8,252 [\$10,757]	\$9,406 [\$10,569]
• VACCINE STORAGE CAPACITY	24 [80] liters	24 [68] liters

*PV array is smaller for large refrigerator due to peculiarities in the World Health Organization specifications.

The bar chart in Exhibit E-15 depicts the ratio of PV- to kerosene-powered vaccine refrigerator life-cycle costs for the best PV case and worst PV case scenarios. Both scenarios assume 20-year life-cycle costing and development agency financing. At an NPV cost ratio of 1.0, PV and kerosene system life-cycle costs are equal. Under the best PV case scenario, the five parameters shown on the graph are adjusted to "reasonable extremes" that favor PV systems. An opposite adjustment is made under the worst PV case scenario.

The sensitivity analyses and the life-cycle cost elements illustrated in Exhibit E-16 indicate which are the most important cost parameters when comparing PV-powered and kerosene-fueled refrigerators. The most critical assumptions are related to vaccine wastage, which is a function of the annual vaccine dose requirement and system operating availability (the percentage of time the system operates within the proper temperature range). It is assumed that because vaccines are a critical item, any vaccine loss due to system unavailability must be replaced through pure cash outlays. The most dominant costs for PV-powered systems are debt service and replacement costs, indicating that refrigerator and battery life are important parameters. The overwhelming cost for kerosene refrigerators is related to vaccine wastage due to the typically low operating availability of kerosene units. Assuming the vaccination program can support the use of a large unit (i.e., have enough vaccines to keep the unit filled), the larger units show lower NPV life-cycle costs. The relative viability of PV versus kerosene units in the small and large cases is approximately the same.

PV-powered vaccine refrigeration systems have demonstrated reliable performance in many developing countries. Operating availability of the PV systems has been significantly higher than that of kerosene-fueled units. The availability of credible data on solar resource and load power consumption under field conditions is fundamental to successful system sizing.

Institutional support is critical to the success of PV-powered vaccine refrigeration systems. Effective user training must be conducted so users understand the operating principles of the system, the consequences of overloading, and the required maintenance procedures. Also, complete coordination with end-user organizations results in an understanding of the particular vaccination program and leads to more efficient and appropriate system designs.

Exhibit E-15

**SENSITIVITY OF REFRIGERATION COSTS
TO BEST AND WORST CONDITIONS**





Exhibit E-16

**BASE-CASE REFRIGERATION SYSTEM
COST COMPONENTS**



3.4 Lighting and Home Power

For this evaluation, the cost of PV and conventional (kerosene lamps and batteries) systems for home power are compared, assuming development agency financing. Exhibit E-17 provides the base-case parameters for this comparison. For the typical small systems examined in this evaluation, PV-powered systems are financially more attractive. For medium and large configurations, PV-powered systems may be financially more attractive, depending on specific technical and financial project parameters.

Exhibit E-17 **LIGHTING AND HOME POWER: BASE CASE**

SPECIFICATIONS:

- Medium Size System - Two Lights
- 20-Watt and 10-Watt Fluorescent Lamps, 6 and 12 hours/day
- Comparison to One Pressurized and One Hurricane Kerosene Fueled Lantern

	PV SYSTEM	KEROSENE SYSTEM
<u>TECHNICAL</u>		
• SYSTEM CONFIGURATION	78 Wp PV array 0.6 kWh battery storage DC fluorescent lights (20W, 10W)	pressurized kerosene lamp hurricane kerosene lamp
<u>FINANCIAL</u>		
• INITIAL CAPITAL COST (FOB)	\$790	\$45
• RECURRING CAPITAL COSTS	\$170 every 5 years	\$45 every 3 years
• MAINTENANCE & REPAIR	4% per year	\$60 per year
• FUEL COSTS	NA	\$109 per year
<u>RESULTS</u>		
• NPV OF 20-YEAR CASH FLOW	\$1,796	\$2,447

In some situations, PV-powered lighting and home power systems have shown viability under shorter loan periods. For example, in French Polynesia, 5-year loans to finance these types of systems have resulted in a substantial expansion of the PV home power market.

The bar charts in Exhibit E-18 depict the ratio of PV- to kerosene-powered home power system life-cycle costs for the best PV case and worst PV case scenarios. Both scenarios assume 20-year life-cycle costing and development agency financing. At an NPV cost ratio of 1.0, PV and diesel system life-cycle costs are equal. Under the best PV case scenario, the five parameters shown on the graph are adjusted to "reasonable extremes" that favor PV systems. An opposite adjustment is made under the worst PV case scenario.

As illustrated in Exhibit E-19, the life-cycle cost of PV home power systems is dominated by debt service (i.e., initial capital cost), reflecting high installed system costs. Kerosene-powered system life-cycle costs are dominated by fuel expenses, followed by maintenance expenses.

The most important technical factor in the successful use of PV-powered lighting and home power systems is the selection of field-proven, reliable charge controllers. The availability and distribution of spare parts for the load and power conditioning equipment is a basic infrastructural need that must be met to ensure successful widespread system implementation.

Exhibit E-18
SENSITIVITY OF HOME POWER COSTS
TO BEST AND WORST CONDITIONS





Exhibit E-19
BASE-CASE LIGHTING AND HOME POWER
SYSTEM COST COMPONENTS



For this evaluation, PV- and diesel-powered multi-use systems are compared, assuming development agency financing. Exhibit E-20 provides the base-case parameters used in this comparison. Multi-use systems are the least-cost option for average energy demands less than 2 kWh/day. Between 2 kWh/day and 16 kWh/day, PV system financial viability is in the break-even range, dependent on case-specific parameters. Above 16 kWh/day, PV multi-use systems are not currently financially viable.

Exhibit E-20
MULTI-USE: BASE CASE

SPECIFICATIONS:

- Load Center - 10 kWh/day Annual Average Demand
- AC System
- Peak Demand = 1.5 X Average Demand

	PV SYSTEM	DIESEL SYSTEM
<u>TECHNICAL</u>		
• SYSTEM CONFIGURATION	3.94 kWp PV array 37.5 kWh battery storage 2 kW Inverter	3kW diesel gen-set
<u>FINANCIAL</u>		
• INITIAL CAPITAL COST (FOB)	\$40,722	\$4,771
• RECURRING CAPITAL COSTS	\$5,625 every 5 years \$3,576 every 10 years	\$4,771 every 6 years 15% every 3 years
• MAINTENANCE & REPAIR	0.1% per year	2% per year
• FUEL COSTS	NA	\$1,704 per year
<u>RESULTS</u>		
• NPV OF 20-YEAR CASH FLOW	\$67,715	\$41,486
• ANNUAL ENERGY GENERATION	3,559 kWh	3,559 kWh

The graph in Exhibit E-21 depicts the ratio of PV- to diesel-powered multi-use system life-cycle costs for the best PV case and worst PV case scenarios. Both scenarios assume 20-year life-cycle costing and development agency financing. At an NPV cost ratio of 1.0, PV and diesel system life-cycle costs are equal. Under the best PV case scenario, the five parameters shown on the graph are adjusted to "reasonable extremes" that favor PV systems. An opposite adjustment is made under the worst PV case scenario. The area between the two curves represents a reasonable range of financial assumptions

Exhibit E-22 depicts the various cost elements of PV- and diesel-powered multi-use systems. In general, PV-powered multi-use system life-cycle costs are dominated by debt service, while diesel system life-cycle costs are dominated by fuel cost. The sensitivity analyses in this chapter indicate that discount rate and fuel cost are the most sensitive parameters when comparing PV-powered multi-use systems to diesel-powered systems.

PV-powered multi-use systems have been successfully fielded; however, the reliability and complexity of power conditioning equipment must be carefully considered when designing these types of systems. As a result of the field performance record of small stand-alone inverters, and a poorly developed infrastructure for maintaining the equipment, applications experts have chosen to design DC systems whenever possible. However, DC is not considered to be a realistic option for mini-utilities. For load centers, the decision between AC and DC is based on the commercial availability of DC appliances.

A local infrastructure for the management of power is required for the successful application of multi-use systems. The energy management structure for PV-powered systems is similar to that for conventional systems. The decision to design one large (mini-utility) system or many decentralized systems (e.g., load centers) is a major rural electrification policy issue.

Exhibit E-21
SENSITIVITY OF MULTI-USE SYSTEM COSTS
TO BEST AND WORST CONDITIONS





Exhibit E-22
BASE-CASE MULTI-USE SYSTEM
COST COMPONENTS



4.0

RECOMMENDATIONS

Based on the review of past projects, current PV technology status, and financial analyses, certain recommendations are made for implementing PV-powered systems in developing countries. These recommendations, outlined in Exhibit E-23, are based on an assessment of those factors that were most prevalent in successful systems and notably absent in unsuccessful systems. Recommendations are oriented towards suppliers, users, and financial institutions.

4.1

Technical

Although most PV systems have performed reliably, there have been some "lessons learned" about system design and operation. Systems that failed usually included: (1) components that were not field tested under similar environmental conditions; (2) systems not properly designed to meet the specified load; or (3) improper system operation. The following recommendations address these three areas of concern:

- Select Field-Proven Components. Successful PV-powered systems have been installed using field-proven components. Failures of these field-proven components have rarely been related to PV as a power source, but rather reflect generic operating experience under developing country conditions.
- Obtain and Properly Use Design Data. Successful PV-powered systems depend on the availability and proper use of credible load, resource, and meteorological data. Specific operating design experience with a number of systems has been used to avoid excessive costs resulting from system overdesign and poor performance due to system underdesign.
- Provide User-Oriented Product Engineering. Minimal instrumentation and simple controls should be used, potential operating errors should be anticipated, and all instruments and controls should be clearly labeled in the appropriate local language. User-oriented product engineering concepts must ultimately be extended to total system design across all PV applications.

Exhibit E-23
RECOMMENDATIONS

TECHNICAL

- **Select Field-Proven Components.** Use PV components and systems that are capable of operating in similar environments.
- **Obtain and Properly Use Design Data.** Use site-specific weather data, where possible.
- **Provide User-Oriented Product Engineering.** Use minimal instrumentation and simple controls.

INSTITUTIONAL

- **Establish Field Service Capability.** Repair capability should be equal to or better than that available for conventional systems.
- **Provide Training At All Levels.** Planners, operators, users, and repair personnel must understand the PV system.
- **Coordinate Activities With End Users.** Local involvement will ensure that local needs are met.

FINANCIAL

- **Evaluate Viability Using Life-Cycle Costing.** PV systems that are cost-effective on a life-cycle basis usually have high initial costs.
- **Utilize Financing Mechanisms for Developing Countries.** Many financing programs are available which could be utilized to minimize the high initial costs of PV systems.

The lack of strong institutional support for operation, maintenance, repair, and training has been the weak link in the successful implementation of PV systems in developing countries. PV systems actually require less institutional support than most conventional systems; however, since PV is a new technology, the minimal support required is often unavailable. This lack of institutional support results in the inability to use an otherwise reliable system and in the false perception that PV, as a technology, is not reliable. The following recommendations are intended to help mitigate these concerns:

- Establish Field Service Capability. Efficiently managing technical support and procuring spare parts is important to the long-term reliable operation of PV-powered systems. Under equally poor infrastructures, PV-powered systems have been shown to be more reliable than conventional alternatives due to their lower requirements for operation, maintenance, and repair.
- Provide Training at All Levels. Suppliers of successful systems have effectively trained users and repair personnel in system operation and the consequences of system misuse. Field reports have indicated that improved user training in basic maintenance and troubleshooting, coupled with adequate documentation (in the local language) and spare parts, can reduce system downtime.
- Coordinate Activities with End-Users. Working with the appropriate host-country agencies to promote feelings among end-users of local ownership and responsibility is vital to successful PV system operation. Taking user expectations and relevant cultural aspects into account throughout the system's design, construction, and operation phases is also important.

The financial analyses demonstrate that PV-powered systems can be the least-cost option on a life-cycle basis, even though their initial capital costs are 50 to 100 percent higher than those of conventional systems. However, for PV systems to gain wide acceptance in developing countries, two actions must occur:

- Evaluate Viability Using Life-Cycle Costing. At high discount and interest rates, PV systems are less attractive because their costs are dominated by a large proportion of levelized debt service. Conventional systems, on the other hand, are dominated by recurring costs, which are reduced at higher discount rates. In light of PV's high initial capital cost, decision-makers responsible for selecting development projects should use life-cycle costing in their financial analysis to ensure that accurate system costs are assessed.
- Utilize Financing Mechanisms for Developing Countries. Most significant development projects in developing countries are funded by long-term loans with favorable terms. These loans are generally provided by development agencies established to promote progress in certain areas of the world. To aid in the continued financing of PV systems, decision-makers must use the many financing mechanisms currently available for developing countries.

Photovoltaic-powered systems have been shown to be a valuable tool to promote progress in the underdeveloped areas of the world. The financial analyses conducted for this evaluation show that small PV systems are generally the least-cost option, even though their initial capital costs are much higher than those of conventional systems. Although in the past there has been some uncertainty and disagreement over the status of PV systems, substantial information now exists that can successfully answer most of these past uncertainties. This information, which is summarized in this report, should help to stimulate the use of PV systems in situations where their application is the most cost-effective and represents the best choice, technically and institutionally.

Distribution - International Systems

Abacus Controls, Inc.
Attn: Mr. George O'Sullivan
P. O. Box 893
Somerville, NJ 08876

Acurex Corporation
Attn: Dan Rosen
555 Clyde Avenue
P. O. Box 7555
Mountain View, CA 94039

AEG Corporation
Attn: Walter J. O'Neill
Bldg. 3 - Suite 130
2222 South Dobson Road
Mesa, AZ 85202-6481

AESI
Attn: Bill Todorof
20442 Sun Valley Drive
Laguna Beach, CA 92651

Alabama Power Co.
Attn: Herbert M. Boyd
600 No. 18th Street
Birmingham, AL 35291

American Power Conversion Corp.
Attn: Mr. Ervin F. Lyon
39 Cambridge Street
Burlington, MA 01803-4115

AMREF
P. O. Box 30125
Nairobi, Kenya

Applied Solar Energy Corp.
Attn: R. F. Brown
15703 E. Valley Blvd.
City of Industry, CA 91749

Appropriate Technology Section
Ministry of Co-ops & Rural Dev.
P. O. Box 686
Maseru 100, Lesotho
AFRICA

ARCO Solar Inc. (4)
Attn: Mr. James Caldwell, Pres.
Mr. Charles Roof
Mr. Ernie Prokopovich
Mr. Michael Rousseau
P. O. Box 2105
Chatsworth, CA 91311

Argonne National Laboratories
Attn: Mr. Allen Evans
4620 No. Park Ave. #156E
Chevy Chase, MD 20815

Arizona Public Service Co.
Attn: Thomas C. Lepley
P. O. Box 53999, Mail Sta. 3875
Phoenix, AZ 85072-3999

Arizona State University
Attn: Paul Russell
College of Engineering
Tempe, AZ 85287

Asion Institute of Technology
Attn: Dr. F. Lasnier
Division of Energy Technology
G.P.O. Box 2754
Bangkok, Thailand

Asion Development Bank
Attn: Mr. Jayonta Madhab,
Energy Advisor
2330 Roxas Blvd.
Metro Manila, Philippines

Associates in Rural Development
Attn: Mr. Richard McGowan
362 Main Street
Burlington, VT 05401

Atlantic Solar Power, Inc.
Attn: Paul G. Apple
6455 Washington Blvd.
Baltimore, MD 21227

Automatic Power
Attn: Mr. Guy Priestley
P. O. Box 18738
Houston, Texas 77223

Balance of Systems Specialists, Inc.
7745 E. Redfield Road
Scottsdale, AZ 85260

Bang-Campbell Associates
Attn: Mr. Richard Campbell
3 Water Street
Woods Hole, MA 02543

Banque Mondiale
Attn: Mr. J. R. Peberdy
Division Chief - WAPAA
Mission Regionale en Africa
B.P. 1850
Abidjon, Ivory Coast

Battelle Columbus Laboratories
Attn: Mr. Gerry Noel
505 King Avenue
Columbus, Ohio 43201

Bechtel National, Inc.
Attn: Mr. Walt Stolte
1. O. Box 3965
San Francisco, CA 94119

Beckwith Electric Company
Attn: Robert W. Beckwith
11811 62nd St. N.
Largo, FL 33543

Best Power Technology, Inc.
P. O. Box 280
Necedah, Wisconsin 54646

BDM Corporation
Attn: Mr. George Rhodes
1801 Randolph Road
Albuquerque, NM 87106

Black and Veatch
Attn: Mr. Sheldon Levy
1500 Meadow Lake Pkwy.
P. O. Box 8405
Kansas City, MO 64114

Blue Sky Water Supply
Attn: Mr. Ronald W. Shaw, Pres.
P. O. Box 21359
Billings, MT 59104

Bonneville Power Adm.
Attn: Minje Ghim
P. O. Box 3621
Portland, OR 97208

Sam Bunker
International Programs Div.(IPD)
Nat'l Rural Elec. Cooperative Assoc.
1800 Massachusetts Avenue, NW
Washington, DC 20036

Buns Philp South Sea Co., LTD.
Attn: Mr. A. J. Jessop
Divisional Manager
Rodwell Rd.
Suva, Fiji

California Energy Comm.
Attn: Mike DeAngelis
1516 9th Street
Sacramento, CA 95814

Capital Goods and Int'l Constr.
International Trade Admin.
Attn: Jim Phillips, Deputy
Asst. Secretary
US Department of Commerce
Washington, DC 20230

Caribbean Agricultural Research
and Development Institute
Attn: Dr. Laxman Singh
P. O. Box 766
Friars Hill
St. John's, Antigua

Caribbean Development Bank
Attn: J. W. Whittingham
Proj. Officer, Tech. & Energy
P. O. Box 408 Wildey
St. Michael
Barbados, W.I.

C.E.R.E.
Attn: Mr. Ibrahima Lo
B.P. 476
Dakar, Senegal

Centre Electronics LTD
Attn: Mr. T. K. Bhattacharya
Project Manager-MASPED Prog.
4 Industrial Area
Sahibabad 201010

Chronar Corp. (2)
Attn: Pandelis Velissopoulos
Avis Harrell
Marketing Dept.
Box 177
Princeton, NJ 08542

Chronar-TriSolar Corp.
Attn: Mr. Anand Rangarajan
10 De Angelo Drive
Bedford, MA 01730

City of Austin Power & Light
Attn: John Hoffner
P. O. Box 1088
Austin, TX 78767

Cleveland State University
Attn: Peter P. Groumpos
1983 E. 24th Street
Cleveland, OH 44115

Coastal Technology, Inc.
Attn: Ms. Cary Boyd
210 Middle Road
Newbury, MA 01922

CODETEL
Attn: Mr. Rafael Zorrilla
P. O. Box 1377
Santo Domingo, Dominican Republic

Colorado State University
Attn: E. V. Richardson,
Campus Project Dir.
Egypt Water Use Mgmt. Project
Fort Collins, CO 80523

Commonwealth of Massachusetts
Attn: Ms. Sharon Pollard
Secretary of Energy
100 Cambridge Street
Boston, MA 02202

Cornell University
Attn: Mr. Joseph K. Campbell
Dept. of Agricultural Eng.
Riley-Robb Hall
Ithaca, NY 14853

Ctr for Engr. and
Environmental Research
Attn: Angel Lopez
College Station
Mayaguez, Puerto Rico 00708

Dames and Moore
Attn: Mr. Dana Younger
7101 Wisconsin Avenue
Suite 700
Bethesda, MD 20814

Danfoss
Attn: Mr. Gerald Bandstra
16 McKee Drive
Mahwah, NJ 07430

Department of Defense
Attn: Mr. Millard Carr
Assistant for Facilities Energy
OASD (MI+L) LM
Pentagon, Room 10760
Washington, DC 20301

Detroit Edison Co.
Attn: George Murray, UTE
2000 2nd Avenue
Rm. 2134 WCB
Detroit, MI 48226

Direccion General de
Telecomunicaciones
203 Isabel La Catolica Street
Santo Domingo, Dominican Republic

Ecodynamics, Inc.
Attn: Mr. Guy R. Webb
8101 Cessna Avenue
Gaithersburg, MD 20879

Economic and Social Commission (2)
for Asia and the Pacific
Attn: Mr. L. N. Fan, Chief
A. S. Manolac
Natural Resources Div.
Bangkok 10200, Thailand

Electric Power and New Energy
Attn: Mr. Endro Utomo Notodisuryo
Director General
Jalan Rasuna Said Kav. 7-8
Jakarta 12950, Indonesia

Electric Power Research Inst. (2)
Attn: John Schaefer
R. Ferraro
P. O. Box 10412
Palo Alto, CA 94303

Electric Research and Mgmt.
Attn: Mr. W. E. Feero
P. O. Box 165
State College, PA 16804

Electrical Review International
Attn: Mr. Tom Dawn
Asst. International Editor
Quadrant House, The Quadrant
Sutton, Surrey SM2 5AS
U.K.

Energia Solar/Conдумex
Attn: Mr. Carlos Flores M.
Sor Juana Ines de la Cruz
344-20 piso
Tlalnepantla, Edo. de Mexico
54000, Mexico

Energy Research and
Development Division
Attn: Mr. Sompongse Chatavorapap
Director
Pibultham Villa
Bangkok 10500, Thailand

Energy Resources International
Attn: Carole Taylor
Golden Gate Energy Center
1055 Fort Cronkhite
Sausalito, CA 94965

ENTECH, Inc.
Attn: Mr. Mark O'Neill
1015 Royal Lane
DFW Airport, TX 75261

Environ Energy Systems, Inc.
P. O. Box 10998-526
Austin, TX 78766-1998

Ms. Debbie Eskenazi
c/o The WUJS Institute
80700 Arad, Israel

Export Council for Renewable Energy
Attn: Mr. Sam Enfield
Suite 503
1717 Massachusetts Ave. NW
Washington, DC 20036

Export-Import Bank of the US
Attn: Mr. John Jennings
Room 1167
811 Vermont Avenue, NW
Washington, DC 20571

Mr. Scott Faiia
c/o CARE
Box 773
Port-au-Prince, Haiti

FAO
Attn: F. J. Moulta
Chief, Environmental Energy
Program - Coordinating Centre
Via delle Terme di Caracalla
00100 Rome, Italy

Farwest Corrosion Control
17311 S. Main Street
Gardena, CA 90248

Mr. Kevin Fitzgerald
575 Cambridge St.
Brighton, MA 02134

Florida Power & Light
Attn: R. S. Allan
P. O. Box 14000
Juno Beach, FL 33408

Florida Power & Light
Attn: Gary L. Michel
P. O. Box 529100
Miami, FL 33152

Florida Solar Energy Center
Attn: Gerald Ventre
300 State Rd. 401
Cape Canaveral, FL 32920

Franklin Electric Co., Inc.
402 E. Spring Street
Bluffton, IN 46714

Gariva Traders
Attn: Mr. D. R. Fernando
Peti Surat 888
Bandar Seri Begawan
Brunei, Borneo

GPL Industries
P. O. Box 306
La Canada, CA 91011

Georgia Power Company
Attn: Mr. Clayton Griffin
P. O. Box 4545
Atlanta, GA 30302

Georgia Power Co.
Attn: Ed Ney
7 Solar Circle
Shenandoah, GA 30265

Mr. Frederic Goldner
448 Neptune Avenue
Brooklyn, NY 11224

Mr. Jim Goodman
P. O. Box 1187
Kathmandu, Nepal

Grundfos
Attn: Mr. Michael Arbon
International a/s
DK-8850 Bjerringbro
Denmark

Grundfos Pumps Corp. (2)
Attn: Mr. John Maxwell
Mr. James Smith
2555 Clovis Ave.
Clovis, CA 93612

Mr. Terence Hart
c/o M. and T. Aroutcheff
Vers Croix Par Usinens 7-4910
Seyssel, France

Health/Population Officer
USAID/Burundi
c/o Department of State
Washington, DC 20520

Hebrew University
Attn: Mr. H. Tabor
Scientific Director
P. O. Box 3745
Jerusalem, Israel

Mr. Jonathon Hodgkin
24 Standish Rd.
Jamestown, RI 02835

Hughes Aircraft Company
Attn: Mr. George Naff
P.O. Box 9399/Bldg. A1, M/S 4C843
Long Beach, CA 90810

Hughes Aircraft Company
Attn: Mr. Bob Vilhauer
International Marketing
Suite 1800
Arlington, VA 22209

HS&T Committee Scientific Advisor
Attn: Dr. Harlan Watson
B374 Rayburn HOB
Washington, DC 20515

Independent Power Co.
Attn: Mr. Sam Vanderhoff
Box 649
North San Juan, CA 95960

Indian Institute of Technology
Attn: Dr. Tara Chandra Kandpal
Centre of Energy Studies
New Delhi-16, INDIA

Institute Piawaian Dan
Attn: Dr. Mustapha Yusoff
Penyelidikan Perindustrian
Lot 10810, Peringkat 3
Peti Surat 35, Shah Alam
Selangor, Malaysia

Instituto Nacional de Energia
Attn: Victor Castellanos
P. O. Box 007-C
Av. Mariano de Jesus No.2307y
Martin de Utreras
Quito, Ecuador

Integrated Power Corporation
Attn: Mr. Brian Kennedy
7524 Standish Pl.
Rockville, MD 20855

Interamerican Development Bank
Attn: Mr. Juan Alfaro
Room 581
801 17th Street, NW
Washington, DC 20006

Intersol Power Corporation
Attn: Mr. John Sanders
11901 W. Cedar Avenue
Lakewood, CO 80228

Iota Engineering
4700 S. Park Ave. - Suite 8
Tucson, AZ 85714

IT Power, Inc. (2)
Attn: Thomas Hoffman
Bernard McNelis
1015 Eighteenth St. NW - Ste. 801
Washington, DC 20036

Irridelco Corp., Inc.
440 Sylan Avenue
Inglewood Cliff, NJ 07632

ISERST/VITA
Attn: Mr. Abdoulbarim Moussa
P. O. Box 486
Djibouti
Republic of Djibouti

Jacuzzi, Inc.
Attn: Mr. Floyd Carter
12401 Interstate 30
P.O. Box 8903
Little Rock, AR 72219-8903

Jensen Brothers Manufacturing Co.
14th and Pacific
P. O. Box 477
Coffeyville, KS 67337

Jet Propulsion Laboratory
Attn: Ronald G. Ross, Jr.
4800 Oak Grove Drive
Pasadena, CA 91109

Mr. Eiren B. Katogui
33 Apo Street
Sta. Mesa Heights
Queyon City, Philippines

Kyocera
Attn: Mr. Luis Alvarez
8611 Balboa Avenue
San Diego, CA 92123-1580

Mr. Brian Latham
Box 2423 - Station D
Ottawa, Ontario
CANADA - K1P 5W5

William Lamb Company
Attn: Mr. William Lamb
10615 Chandler Blvd.
North Hollywood, CA 91601

Mr. Mark K. Levenson
1415 Alta Mesa Drive
Brea, CA 92621

Levitt and Company, Inc.
Attn: Mr. Jim Levitt
50 Church Street
Cambridge, MA 02138

March Manufacturing Co.
1819 Pickwick Avenue
Glenview, IL 60025

Ms. Aubrey Marks
343 Middle Street
Georgetown, Guyana

Marvel
Attn: Mr. Richard Detrick
P. O. Box 997
Richmond, Indiana 47374

Mass PV Center (2)
Attn: Kevin Collins
Jane Weissman
1 Mass Tech Center
So. Access Road - Logan Airport
East Boston, MA 02128

A. Y. McDonald Mfg. Co.
Attn: Mr. John D. Eckel
4800 Chavenelle Road
Dubuque, IA 52001

Meridian Corporation (5)
Attn: Mr. Brad MacAleer
Judith M. Siegel
David Kerner
Larry Slominski
Judy Laufman
113 Leesburg Pike, Suite 700
Halls Church, Virginia 22041

Ministry of Energy
P.O. Box 7758
Harare, Zimbabwe

Ministry of Energy & Reg. Dev.
Attn: Mr. Sadique Mullei
Solar & Wind Energy Division
P.O. Box 30582
Nairobi, Kenya

Global Solar Energy Corp. (2)
Attn: Mr. Bob Hammond
Mr. Paige Duffy
6 Hickory Drive
Northampton, MA 02254

Mr. Freddie Motlhattedi
c/o MMRWA
Private Mail Bag 0018
Gaborone, Botswana

ASA Lewis Research Center
Attn: Mr. Anthony Ratajczak
1000 Brookpark Road
Cleveland, OH 44135

National Association of
Home Builders
Attn: Michael Bell
5th and M Street NW
Washington, DC 20036

Natural Power, Inc.
Attn: Brian Gordon
Rancetown Turnpike
New Boston, NH 03070

Naval Civil Engineering Lab
Attn: Kwang Ta Huang
ODE L 72
Port Hueneme, CA 93043

Naval Weapons Center
Attn: G. Smith
Code 02A1
China Lake, CA 93555-6001

New England Power Service
Attn: Mr. Edward Gulachenski
25 Research Drive
Westborough, MA 01581

Newline Trading
Attn: Mr. Michael Thome
P.O. Box 3932
Samabula
Suva, Fiji

Robert Nicolait and Assoc.
Attn: Mr. Robert Nicolait
P.O. Box 785
Belize City, Belize

NRED/TCD
Attn: Mr. Derek Lovejoy
Interregional Advisor
Energy Resources Branch
United Nations, NY 10017

Office of the US Trade Rep.
Attn: Mr. Bob Reinstein
Dir. Energy and Chem. Trade Policy
600 17th Street NW
Washington, DC 20506

Office of Management and Budget
Attn: Mr. Randy Steers
New Executive Office Bldg.
17th & Penn. Ave. NW - Rm. 8013
Washington, DC

Omnion Power Engineering
Attn: Mr. Hans Meyer
W297 S11085 Hwy. ES
Mukwonago, WI 53149

OPIC
Attn: Mr. Gerald West
Vice President for Development
1615 M Street, NW
Washington, DC 20527

Pacific Gas & Electric Co.
Attn: Steve Hester
3400 Crow Canyon Road
San Ramon, CA 94583

Pakistan Council of Science
and Industrial Research
Attn: Mr. M. Saif-ul-Rehman
Principal Scientific Officer
Shahrah-E-Jalal-UD-Din Room 1
Lahore - 16, Pakistan

Photocomm, Inc.
Attn: Mr. Joseph Garcia
7735 East Redfield
Scottsdale, AZ 85260

Photovoltaics International
Attn: Mark Fitzgerald
Box 1467
Denver, CO 80201

PNOC-Energy Research and
Development Center
Attn: Henry Ramos
Head, Solar Energy Division
Don Mariano Marcos Ave.
Queyon City, Philippines

PV Energy Systems, Inc.
Attn: Mr. Paul Maycock
P. O. Box 290
Casanova, VA 22017

Polar Products
Attn: Mr. Authur Sams
2908 Oregon Court
Building 1-11
Torrance, CA 90503

Princeton University
Attn: Dr. Sam Baldwin
Center for Engineering and
Environmental Studies
H-206 Engineering Quadrangle
Princeton, NJ 08541

Public Service Co. of New Mexico
Attn: Mr. R. Michael Lechner
Alvarado Square
Albuquerque, NM 87158

Public Service Elec. & Gas. Co.
Attn: Mr. Harry Roman
80 Park Plaza
P. O. Box 80
Newark, NJ 07101

Pulstar
619 South Main St.
Gainesville, FL 32601

Renewable Energy Institute
Attn: Robert Hayden
1516 King Street
Alexandria, VA 22314

Renewable Energy Institute
Attn: Mr. Carlo LaPorta
Room 719
1001 Connecticut Ave., NW
Washington, DC 20036

Research Triangle Institute (2)
Attn: Carl Parker
Allan Wyatt
P. O. Box 12194
Research Triangle Park, NC 27709

Robbins and Myers
P. O. Box 965
Springfield, OH 45501

Mr. George Royal
2532 Eye Street NW
Washington, DC 20037

SAIC
Attn: Douglas Danley
1710 Goodridge Drive
McLean, VA 22102

Salt River Project
Attn: Mr. Steve Chalmers
P. O. Box 1980
Phoenix, AZ 85001

San Diego State University
Attn: Mr. Al Sweedler
Dir., Center for Energy Studies
Department of Physics
San Diego, CA 92182

San Diego Gas & Electric
Attn: Don E. Fralick
P. O. Box 1831
San Diego, CA 92112

Mr. Hans Dieter Sauer
Hiltstrasse 10
8035 Gauting
West Germany

Senakangoeli Solar Systems
Attn: Mr. Gary Klein
P. O. Box 4375
Sebaboleng 104, Lesotho

Mr. Stan Simmons
1728 Pitcher Canyon Road
Wenatchee, WA 98801

Simpler Solar Systems
3120 W. Thorpe
Tallahassee, FL 32302

Six Rivers Solar, Inc.
Attn: Greg Williams
818 Broadway
Eureka, CA 95501

Solar Economics, Inc.
Attn: Martin Katzman
7271 Dye Drive
Dallas, TX 75248

Solar Electric Engineering
Attn: Hugh Diaz
405 East "D" St.
Petaluma, CA 94952

Solar Electric International
Attn: Mr. John M. Williams
77 Industrial Estate
Luqa, Malta

Solar Electric Specialties
Attn: Jim Welch
1558 Riverside
Fort Collins, CO 80524

Solar Energy Research Inst. (2)
Attn: Richard DeBlasio
Jack Stone
1617 Cole Blvd.
Golden, CO 80401

Solar Engineering Services
Attn: Mr. Tim Ball
P. O. Box 7122
Olympia, WA 98507

Solar Trade International
Attn: Manuel J. Blanco
630-6th Avenue - Suite 2M
San Francisco, CA 94118

Solarex Corporation (2)
Attn: Mr. Malcolm L. Ream
Mr. Dan Bumb
Mr. Ted Blumenstock
Mr. Bill Rever
1335 Piccard Drive
Rockville, MD 20850

Solarpak Limited
Attn: Mr. Graeme Finch
Factory Three, Cock Lane,
High Wycombe
Bucks HP13 7DE, England

Solar Voltaics
Attn: Mr. Lennart Muiggi
A-6166 Fulpmgs-Innsbruck
(R-Bank-Bldg.)
Kirchstr 3, Austria

Solavolt International (2)
Attn: Mr. Paul Garvison
Mr. Bill Kaszeta
P. O. Box 2934
Phoenix, AZ 85062

Solec International, Inc.
Attn: Ishaq Shahryar
12533 Chadron Avenue
Hawthorne, CA 90250

Southern California Edison
Attn: Mr. Nick Patapoff
P. O. Box 800
Rosemead, CA 91770

Southern Company Services
Attn: Mr. J. Timothy Petty
P. O. Box 2625
Birmingham, AL 35202

Sovonics Solar Systems
Attn: Mr. Jack Carter
6180 Cochran Road
P. O. Box 39608
Solon, OH 44139

Specialty Concepts, Inc.
9025 Eton Ave., Suite D
Canoga Park, CA 91304

Spire Corporation
Attn: Mr. Roger Little
Patriots Park
Bedford, MA 01730

Stone & Webster Engr. Corp.
Attn: Mr. Duncan Moodie
245 Summer St.
Boston, MA 01921

Strategies Unlimited (2)
Attn: Mr. Bill Murray
Mr. Robert Steele
201 San Antonio Circle
Suite 205
Mountain View, CA 94040

Sun Amp Systems, Inc.
7702 East Gray Road
Scottsdale, AZ 85260

SunWalt
Attn: Mr. Richard Komp
Route 2
English, IN 47118

Sun Watt International Ltd.
P. O. Box 24167
Denver, CO 80224

Swedish Telecom International
Attn: Mr. John Blaxland
P. O. Box 7585
Stockholm, Sweden

SW RES Experiment Station
Attn: Vern Risser
New Mexico State University
Box 3SOL
Las Cruces, NM 88003

Tennessee Valley Authority
Attn: Joan Wood
Solar Applications Branch
350 Credit Union Building
Chattanooga, TN 37401

The Director of LESO
Cheickna Traore
B.P.I. 34
Bamako, Mali

Thermo-Electron
Attn: Mr. Barry Welch
Energy Systems Division
P. O. Box 9047
Waltham, MA 02254-9047

Tideland Signal Corp.
Attn: Mr. Harry Saenger
4310 Director's Row
P. O. Box 52430
Houston, TX 77052

Mr. Mohammed-Ali Toure
Director General
Villa 21 A Zone-B
Sinaes a. doquerre
B.P. 1277
Dakar, Senegal

UN Development Program
Attn: Mr. R. S. Ragde
Energy Office
One United Nations Plaza
New York, NY 10017

UN Educational, Scientific and
Cultural Organization
Attn: Mr. T. Beresovski
7 Place de Fontenoy
75700 Paris, France

UN Regional Office for Africa
Attn: Dr. Yehia El Mahgary
Senior Programme Officer
P. O. Box 30552
Nairobi, Kenya

University of Bangui (2)
Attn: Dr. Jean-Marie Bassia
Dr. Joachim Sicke-Raimalby
Central African Republic
Bangui, C.A.R.

University of Guam
Attn: Steven Winter, Dir.
Water and Energy Research Inst.
UOG Station
Mangilao, Guam 96913

University of Lowell (2)
Attn: Jose Martin
Mechanical Engineering Dept.
Lowell, MA 01854

University of Lowell
Attn: Thomas Costello
Fahd Wakim
1 University Avenue
Lowell, MA 01854

University of Michigan
Attn: Mr. Allen Roberts
Center for Afro-American/African
Studies
200 West Engineering
Ann Arbor, MI 48109

University of Sains Malaysia
Attn: Dr. Donald Chuah Guan Siong
School of Physics
Penang, Malaysia

University of Technology
Attn: Mr. R. Burton
P. O. Box 793
Papua, New Guinea

University of Texas
at Arlington
Attn: Jack Fitzer
West 6th at Speer Street
Arlington, TX 76019

Utah State University
Attn: Mr. Gaylord Skogerboe
Dir. Int'l Irrigation Center
UMC 8313
Logan, UT 84322

U.S. Agency for International
Development (USAID)
Attn: Mr. Jack Vanderryn
Director, Energy and Natural
Resources
Rm. 509, SA-18
Washington, DC 20523

U.S. Agency for Int'l Development
Attn: Ms. Carolyn Coleman
Bureau for Asia
Room 6754
Washington, DC 20523

U.S. Agency for Int'l Development
Attn: Mr. Weston Fisher
Energy Advsr-West/Cen.Africa
Bureau for Africa
Room 2480 NS
Washington, DC 20523

U.S. Agency for Int'l Development (2)
Attn: Mr. Jim Hester
Ms. Mary Lou Higgins
Bureau for Latin America and Car.
Room 2239 NS
Washington, DC 20523

USAID/Guatemala
Energy Officer
APO Miami, FL 34024

U.S. Agency for Int'l Development
Attn: Mr. Robert Ichord
Chief-Energy, Forestry, Env. Div.
Bureau for Asia
Room 3311 NS
Washington, DC 20523

U.S. Agency for Int'l Development (205)
Attn: Mr. Alan Jacobs
Mr. David Jhirad
Mr. Samuel Schweitzer
Mr. James Sullivan
Ms. Shirley Toth (200)
Ms. Janine Fimmel
Bureau for Science and Technology
Room 508 SA-18
Washington, DC 20523

USAID/Cost Rica
Attn: Mr. Heriberto Rodriguez
General Engineer
APO Miami, FL 34020

USAID/Egypt
Attn: Mr. Eric Peterson
Cairo, Egypt

USAID/Haiti
Attn: Mr. John W. Airhart
Department of State
Washington, DC 20520

USAID/Jakarta
Attn: Mr. Desmond O'Riordan
Chief, Div. of Eng. and Science
Indonesia

USAID/Liberia
Attn: Mr. Robert Broden
APO New York, NY 09155

USAID/Paraguay
Attn: Mr. Paul Frity
Development Attache
Asuncion, Paraguay

USAID Representative
Attn: Mr. Neboysha R. Broshich
US Embassy
Belize City, Belize

USAID/Mission to Dominican Republic
Attn: Mr. Leo Perez Minaya
Energy Project Advisor
APO Miami, FL 34041-0008

USAID/Morocco
Attn: Mr. S. R. Nevin
Rabat, Morocco

USAID/Quito Ecuador
Attn: Mr. Fausto Maldonado
Project Specialist
c/o Department of State
Washington, DC 20523

USAID/Thailand
Attn: Mr. John W. Neave
Dir., Office of Engineering
37 Soi Sonprasong 3
Petchaburi Road
Bangkok, Thailand

USAID/Zaire
Attn: Ms. Debra A. Rectenwald
Mission Evaluation Officer
Zaire, Africa

U.S. Congress
Office of Technology Assessment
Attn: Mr. Peter Blair
Energy and Materials Program
Washington, DC 20510

U.S. Department of Commerce
Attn: Mr. Les Garden
Renewable Energy Industry Spclst.
Int'l Trade Admin. - Rm. 2811
Washington, DC 20230

U.S. Department of Energy (6)
PV Energy Technology Division
Attn: Mr. R. H. Annan
Mr. A. Krantz
Mr. V. Rice
Ms. Elaine Guthrie
Mr. M. Prince
Mr. M. Pulscak

1000 Independence Avenue SW
Washington, DC 20585

U.S. Dept. of Energy
Attn: Dean Graves
Energy Technology Division
Albuquerque Operations Office
Albuquerque, NM 87115

U.S. Department of Energy
Attn: Leonard J. Rogers
Wind/Ocean Technologies Div.
1000 Independence Ave. SW
Washington, DC 20585

U.S. Department of Energy
Attn: J. Rumbaugh
DOE/Wind Systems
1000 Independence Ave., SW
Washington, DC 20585

U.S. Department of State
Attn: Mr. Martin Prochnik
Dir., Energy Technology
Cooperation Division
Washington, DC 20520

US Department of State
Attn: Mr. Joe Sconce
Regional Dir., for Latin America
Trade and Development Program
Washington, DC 20523

U.S. Virgin Islands Energy Office
Institutional Conservation Program
Lagoon Complex, Bldg. 3, Room 233
St. Croix, U.S. Virgin Islands 00840

U.V. International
Attn: Mr. Vimal Jhunjhunwala
Vice President
17150 Norwalk Blvd. Ste. 118
Cerritos, CA 90701

Mr. Karl Van Wesel
LPH 300
Talbot Square
London W2 ITT, U.K.

Mr. Larry Van Zee
Box 228
Kontagoia
Niger State, Nigeria

VITA
Attn: Ms. Donna Reed
Suite 200
1815 N. Lynn Street
Arlington, VA 22209

VITA Djibouti
Attn: Mr. Steve Hirsch
Djibouti City, Djibouti

Mr. George Warfield
RD2 Box 264
Vergennes, VT 05491

Warns Solar Pumps
Attn: Mr. Robert Meyer
246 East Irving
Wood Dale, IL 60191

Mr. James Welsh
1528 Riverside Avenue
Fort Collins, CO 80524

World Health Organization
Attn: Mr. John Lloyd
20, Avenue Appia, 1211
Geneva 27, Switzerland

WHO/PAHO
Attn: Mr. Peter Carrasco
Expanded Program on Immun.
525 23rd Street, NW
Washington, DC 20037

World Bank (2)
Attn: Mr. Richard Dosik
Mr. Rene Moreno
Energy Department
1818 H Street NW
Washington, DC 20433

World Bank
Attn: Mr. Devbrat Dutt
Bldg. C-607
1818 H Street NW
Washington, DC 20433

World Bank
Attn: Mr. Alfonso Zavala
Water Supply & Urban Development
1818 H Street - Room N-729
Washington, DC 20433

World Bank
Attn: Mr. A. Amir Al-Kafaji
Chief, Water Supply Division
W. Africa Project Department
1818 H Street NW
Room C-309
Washington, DC 20433

3141 S. A. Landenberger (5)
3151 W. L. Garner (3)
3154-3 C. H. Dalin (28)
for DOE/OSTI

6200 V. L. Dugan
6220 D. G. Schueler
6221 E. C. Boes
6221 M. G. Thomas
6223 G. J. Jones
6223 H. N. Post (80)
6224 D. E. Arvizu
8024 P. W. Dean